



**HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT**
e-mail id: ee-shahpur-pwd@hp.gov.in



No. PWD/SD/WA/School Safety/2025-26/- 9991

Dated: 23/02/26

To


The Principal,
Highland Public School,
Village Ruhru, Post Office Sudher,
Teh. Shahpur Distt Kangra H.P


Subject: - School Building Safety Certificate.



Reference:- Assistant Engineer, Sub Division, HPPWD Gaggal letter No. 1132-33 dated 18-02-2026.

With reference to the Assistant Engineer, HPPWD, Sub Division Gaggal office letter under reference, the school building safety certificate is sent herewith for information.

DA: as above


Manager
Highland Public School
Vill. Ruhru, P.O. Sudher
Dharamshala (H.P.) - 176215



Principal
Highland Public School
Vill. Ruhru, P.O. Sudher
Dharamshala (H.P.) - 176215



Executive Engineer
Shahpur Division
HP.PWD Shahpur



TO WHOM IT MAY CONCERN

The School building of Highland Public School Village Ruhru Post. Office Sudher Tehsil Dharamshala District Kangra (HP) was constructed during the year 2019-20 as per the report of the Principal of concerned school /Pardhan Gram Panchyat Sudher . As per the school authorities the architectural drawing of the school building drawing submitted to this office only . The above building has been inspected by the Junior Engineer on dated 17.02.2026. The building has neither been designed been supervised by this department and no structural design was supplied by the school authorities and hence it is not possible to analyses and check the structural stability specifically from earthquake point of view of the existing building as hidden dimension and reinforcement could not be verified .


However as per visual inspection / physical appearance the building appear to be safe under static loads at present . But this department will not be responsible for any loss of life of property etc, if this structure falls under any circumstances no officer/official of this office will attend /plead in any Hon'ble court in case of any dispute of miss-happening regarding the structure failure of this building . Therefore , the safety certificate is hereby issued for the period 01.04.2026 to 31.03.2027 on the basis of physical appearance of building only .


Junior Engineer
Gaggal Section


Assistant Engineer,
Gaggal Sub-Division,
HPPWD Gaggal.


Executive Engineer
Shahpur Division
HPPWD Shahpur.


Manager
Highland Public School
Vill. Ruhru, P.O. Sudher
Dharamshala (H.P.) - 176215


Principal
Highland Public School
Vill. Ruhru, P.O. Sudher
Dharamshala (H.P.) - 176215